

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3225-1328:115 Page 1 of 1

**CATEGORY:** Fire Dampers

**LISTEE:** Air Balance, 7301 International Drive, Holland OH 43528  
Contact: \*Chuck Schneider (419) 865-5000

**DESIGN:** Model FT fire damper. Parallel blade design, single and multiblade type construction. 5-1/2" x 16 Ga. galvanized steel frame; 7-3/4", 5-3/4" and/or 3-3/4" wide x minimum 16 Ga. galvanized steel blades; 1/2" square plated, galvanized or stainless steel blade axles; and 20 Ga. minimum sleeves thickness. Maximum single section is 42" wide x 48" high and multiple section is 126" wide x 48" high. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 3 Hour

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as 3-hour fire-rated damper for use in air conditioning and ventilation ducts to protect openings. For vertical installations only.

**NOTE:** Leakage rating not evaluated.

\*Rev. 08-23-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 19, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**